

LAMPIRAN C

SIMULASI

PT. PLN (PERSERO) AREA BIMA

NO	URAIAN	SATUAN	TEGANGAN PELAYANAN		Ket
			TM	TR	
1	PENJUALAN	KWh	9,232,899	194,763,152	
2	VA TERSAMBUNG	VA	4,346,250	133,793,848	
3	JAM NYALA RATA-RATA	JAM/BULAN	318.30	3493.38	
4	LOAD FACTOR RATA-RATA	%	0.74	0.55	
5	SUSUT JARINGAN	%	0.24	0.98	
6	SUSUT JARINGAN	kWh	544,413	2,081,088	
7.1	SAIDI	JAM/PEL/TH	0:00:20	0:01:15	
7.2	SAIFI	KALI/PEL/TH	1.16429	2.4762	
7.3	VARIASI TEGANGAN	%	13.50	31.36	
7.1.1	FAKTOR SAIDI		8,759.9998	8,759.9991	
7.2.1	FAKTOR SAIFI		43,184,884.0245	24,919,367.2292	
7.3.1	FAKTOR TEGANGAN UJUNG		1	0.84	
8	JUMLAH PELANGGAN		12	167,169	
9	PANJANG JARINGAN		1245 Kms	924 Kms	
10	IPBT 2015		705,018,599,178,470,000,000	154,316,986,566,113,000,000,000	
11	RASIO IPBT 2015		0.00	1.00	1.00