

PERHITUNGAN ARUS GANGGUAN HUBUNG SINGKAT

PANJAR		lf3fasa	lf2fasa	lf1fasa
(KM)	(%)	(amp)	(amp)	(amp)
0.1	1%	13242.84	11468.64	954.80
0.3	5%	12887.63	11161.01	951.36
0.6	10%	12451.90	10783.66	947.08
0.9	15%	12028.06	10416.61	942.85
1.2	20%	11618.16	10061.62	938.64
1.5	25%	11223.53	9719.87	934.48
1.8	30%	10844.95	9392.00	930.35
2.1	35%	10482.74	9078.32	926.25
2.4	40%	10136.91	8778.82	922.19
2.7	45%	9807.21	8493.29	918.17
3	50%	9493.23	8221.38	914.17
3.3	55%	9194.44	7962.62	910.21
3.6	60%	8910.22	7716.47	906.29
3.9	65%	8639.90	7482.37	902.39
4.2	70%	8382.81	7259.72	898.53
4.5	75%	8138.26	7047.94	894.70
4.8	80%	7905.57	6846.42	890.90
5.1	85%	7684.09	6654.61	887.13
5.4	90%	7473.17	6471.95	883.39
5.7	95%	7272.21	6297.92	879.68
6	100%	7080.63	6132.01	876.01