

Arus Hubung Singkat GI/GITET P2B Triwulan 1 Tahun 2017

No.	Bus	GI/GITET	APB	TEG	Impedansi Urutan Positif		Impedansi Urutan Negatif		Impedansi Urutan Nol		Arus Hubung Singkat	
				kV	R1(pu)	X1(pu)	R2(pu)	X2(pu)	R0(pu)	X0(pu)	1ph(kA)	3ph(kA)
92	I-5	DURIKOSAMBI	APB DKI Jakarta Banten	150	0.00066221	0.01076773	0.00052531	0.00993142	0.00139122	0.00802154	43.820	39.114
93	II-5	DURIKOSAMBI	APB DKI Jakarta Banten	150	0.00066221	0.01076773	0.00052531	0.00993142	0.00139122	0.00802154	43.820	39.114
94	III	DURIKOSAMBI	APB DKI Jakarta Banten	150	0.00066221	0.01076773	0.00052531	0.00993142	0.00139122	0.00802154	43.820	39.114
95	IV	DURIKOSAMBI	APB DKI Jakarta Banten	150	0.00066221	0.01076773	0.00052531	0.00993142	0.00139122	0.00802154	43.820	39.114