

LAPORAN HASIL PENGUKURAN BEBAN GARDU DAN TEGANGAN UJUNG

NOMOR DOKUMEN : RM - 02 - KBJ



1	NOMOR GARDU	:	KJ 60	TRAFO :	:		DAYA :	630	KVA	URAIAN	TYPE	MERK	JUR	PENGUKURAN TEGANGAN					
	PENYULANG	:	KODAK	MERK :	:	UNINDO	1995	NO. :	61067	1. KUBIKEL :				DI RAK TR (VOLT)					
	GARDU INDUK	:	KEMBANGAN	BUSHING TM :		KERING		TRAP :		1	2. KUBIKEL :			RS	ST	RT	RN	SN	TN
	ALAMAT GARDU	:	JL. PERMATA BU	RAK TR MERK :				JUR :		8	3. KUBIKEL :			VOLT					
	TYPE GARDU	:	BETON	HANDLE MERK :		SOCOMEK		KAP :	1250	AMP	4. KUBIKEL :			375	373	371	215	215	214
	LAMPU GARDU	:		TEST :	-	GFD MERK :		TEST :			5. KUBIKEL :								
	DAERAH PELAYANAN	:	PT. PLN AREA KEBON JERUK								6. KUBIKEL :								
											7. KUBIKEL :								
	KUNCI GARDU MERK :		CYB	KONDISI :	BAIK	DI UKUR JAM :	11:03	TGL :	10 SEPT 2018		8. KUBIKEL :								
											9. KUBIKEL :								

NO	JURUSAN		OPSTYK KABEL		BEBAN DAN NH FUSE TERPASANG FUSE (A)										TEGANGAN UJUNG						BEBAN TRAFO		KETERANGAN
					R			S			T			N	RS	ST	RT	RN	SN	TN			
	KODE	JURUSAN PELAYANAN	TYPE	PENAMPANG KABEL	BEBAN	FUSE	COSØ	BEBAN	FUSE	COSØ	BEBAN	FUSE	COSØ	BEBAN	VOLT						KVA	%	
1	A		CU	4 X 95	87	250		111	400		142	300		43				203	201	201	72,99	11,59	
2	B		CU	4 X 95	11	250		58	400		72	250		60							30,27	4,80	
3	C		CU	4 X 95	41	400		25	250		34	400		12							21,47	3,41	
4	D		CU	4 X 95	92	400		171	300		126	400		58							83,51	13,25	
5	E		CU	4 X 95	34	250		15	300		29	250		24							16,74	2,66	
6	F		CU	4 X 95	29	300		29	300		47	315		18							22,54	3,58	
7	G		CU	4 X 95	22	300		63	315		67	300		35							32,63	5,18	
8	H		CU	4 X 95	48	400		73	315		49	315		22							36,49	5,79	
9	I																						
10	J																						
JUMLAH					364			545			566			272							316,63	50,26	
JUMLAH TOTAL					1475									AMP							316,63	50,26	

CATATAN : _____

SPV. OPDIST. KBJ

PENGATUR

JAKARTA, 10 SEPTEMBER 2018

PETUGAS

TITO SUJARWADI

SLAMET RIYANTO

MASRIZAL / DWI