



LAPORAN HASIL PENGUKURAN BEBAN GARDU DAN TEGANGAN UJUNG

NOMOR DOKUMEN : RM - 02 - KBJ



1	NOMOR GARDU	:	KJ 60	TRAFO :	:		DAYA :	630	KVA	URAIAN	TYPE	MERK	JUR	PENGUKURAN TEGANGAN					
	PENYULANG	:	KODAK	MERK :	:	UNINDO	1995	NO. :	61067	1. KUBIKEL :				DI RAK TR (VOLT)					
	GARDU INDUK	:	KEMBANGAN	BUSHING TM :		KERING		TRAP :		1	2. KUBIKEL :			RS	ST	RT	RN	SN	TN
	ALAMAT GARDU	:	JL. PERMATA BU	RAK TR MERK :				JUR :		8	3. KUBIKEL :			VOLT					
	TYPE GARDU	:	BETON	HANDLE MERK :		SOCOMEK		KAP :	1250	AMP	4. KUBIKEL :			388	386	385	218	219	218
	LAMPU GARDU	:		TEST :	-	GFD MERK :		TEST :			5. KUBIKEL :								
	DAERAH PELAYANAN	:	PT. PLN AREA KEBON JERUK								6. KUBIKEL :								
											7. KUBIKEL :								
	KUNCI GARDU MERK :		CYB	KONDISI :	BAIK	DI UKUR JAM :	19:00	TGL :	07 SEPT 2018		8. KUBIKEL :								
											9. KUBIKEL :								

NO	JURUSAN		OPSTYK KABEL		BEBAN DAN NH FUSE TERPASANG FUSE (A)										TEGANGAN UJUNG						BEBAN TRAFO		KETERANGAN
					R			S			T			N	RS	ST	RT	RN	SN	TN			
	KODE	JURUSAN PELAYANAN	TYPE	PENAMPANG KABEL	BEBAN	FUSE	COSØ	BEBAN	FUSE	COSØ	BEBAN	FUSE	COSØ	BEBAN	VOLT						KVA	%	
1	A		CU	4 X 95	177	250		145	400		169	300		67				207	204	203	107,20	17,02	
2	B		CU	4 X 95	48	250		113	400		93	250		73							55,46	8,80	
3	C		CU	4 X 95	81	400		53	250		68	400		30							44,10	7,00	
4	D		CU	4 X 95	170	400		166	300		178	400		56							112,22	17,81	
5	E		CU	4 X 95	35	250		26	300		36	250		32							21,18	3,36	
6	F		CU	4 X 95	65	300		70	300		87	315		24							48,47	7,69	
7	G		CU	4 X 95	41	300		91	315		27	300		21							34,72	5,51	
8	H		CU	4 X 95	94	400		118	315		159	315		26							81,00	12,86	
9	I																						
10	J																						
JUMLAH					711			782			817			329							504,35	80,06	
JUMLAH TOTAL					2310									AMP							504,35	80,06	

CATATAN : _____

SPV. OPDIST. KBJ

TITO SUJARWADI

PENGATUR

USMANSYAH SE

JAKARTA, 07 SEPTEMBER 2018

PETUGAS

SUHARI / FUAD Q