

LAPORAN HASIL PENGUKURAN BEBAN GARDU DAN TEGANGAN UJUNG

NOMOR DOKUMEN : RM - 02 - KBJ



1	NOMOR GARDU	:	D 58N	TRAFO :	:		DAYA :	630	KVA	URAIAN	TYPE	MERK	JUR	PENGUKURAN TEGANGAN					
	PENYULANG	:	ANGSANA	MERK :	:	STARLITE	2008	NO. :	0705891045-1	1. KUBIKEL :				DI RAK TR (VOLT)					
	GARDU INDUK	:	KEBON JERUK	BUSHING TM :		KERING		TRAP :	3	2. KUBIKEL :				RS	ST	RT	RN	SN	TN
	ALAMAT GARDU	:	JL. ANGGREK R	RAK TR MERK :				JUR :	8	3. KUBIKEL :				VOLT					
	TYPE GARDU	:	BETON	HANDLE MERK :		SOCOMEK		KAP :	2000	AMP	4. KUBIKEL :			393	392	393	225	225	223
	LAMPU GARDU	:		TEST :	-	GFD MERK :		TEST :		5. KUBIKEL :									
	DAERAH PELAYANAN	:	PT. PLN AREA KEBON JERUK								6. KUBIKEL :								
											7. KUBIKEL :								
	KUNCI GARDU MERK :		CYB	KONDISI :	BAIK	DI UKUR JAM :	10:52	TGL :	16 AGUST 2018	8. KUBIKEL :									
											9. KUBIKEL :								

NO	JURUSAN		OPSTYK KABEL		BEBAN DAN NH FUSE TERPASANG FUSE (A)										TEGANGAN UJUNG						BEBAN TRAFO		KETERANGAN
					R			S			T			N	RS	ST	RT	RN	SN	TN			
	KODE	JURUSAN PELAYANAN	TYPE	PENAMPANG KABEL	BEBAN	FUSE	COSØ	BEBAN	FUSE	COSØ	BEBAN	FUSE	COSØ	BEBAN	VOLT						KVA	%	
1	A		CU	4 X 95	123	BC		132	355		86	355		44				214	213	210	76,50	12,14	
2	B		CU	4 X 95	42	400		59	400		33	355		22							30,06	4,77	
3	C		CU	4 X 95	70	315		100	400		149	250		48							71,56	11,36	
4	D		CU	4 X 95	98	250		78	BC		72	BC		21							55,63	8,83	
5	E		CU	4 X 95	36	250		45	250		40	250		12							27,14	4,31	
6	F		CU	4 X 95	93	BC		85	300		91	BC		15							60,35	9,58	
7	G		CU	4 X 95	56	315		54	200		67	315		12							39,71	6,30	
8	H	KOSONG																					
9	I																						
10	J																						
JUMLAH					518			553			538			174							360,95	57,29	
JUMLAH TOTAL					1609									AMP							360,95	57,29	

CATATAN : _____

SPV. OPDIST. KBJ

PENGATUR

JAKARTA, 16 AGUSTUS 2018

PETUGAS

TITO SUJARWADI

SLAMET RIYANTO

MASRIZAL / DWI