

LAPORAN HASIL PENGUKURAN BEBAN GARDU DAN TEGANGAN UJUNG

NOMOR DOKUMEN : RM - 02 - KBJ



1.	NOMOR GARDU	:	D 58N	TRAFO	:	:	DAYA	:	630	KVA	URAIAN	TYPE	MERK	JUR	PENGUKURAN TEGANGAN							
	PENYULANG	:	ANGSANA	MERK	:	:	STARLITE	2008	NO.	:	0705891045-1	1. KUBIKEL	:	:	:	DI RAK TR (VOLT)						
	GARDU INDUK	:	KEBON JERUK	BUSHING TM	:	:	KERING		TRAP	:	3	2. KUBIKEL	:	:	:	RS	ST	RT	RN	SN	TN	
	ALAMAT GARDU	:	JL. ANGGREK R	RAK TR MERK	:	:			JUR	:	8	3. KUBIKEL	:	:	:	VOLT						
	TYPE GARDU	:	BETON	HANDLE MERK	:	:	SOCOMEK		KAP	:	2000	AMP	4. KUBIKEL	:	:	396	397	393	227	228	228	
	LAMPU GARDU	:		TEST	:	-	GFD MERK	:	TEST	:		5. KUBIKEL	:	:	:							
	DAERAH PELAYANAN	:	PT. PLN AREA KEBON JERUK										6. KUBIKEL	:	:	:						
													7. KUBIKEL	:	:	:						
	KUNCI GARDU MERK	:	CYB	KONDISI	:	BAIK	DI UKUR JAM	:	19:00	TGL	:	16 AGUST 2018	8. KUBIKEL	:	:	:						
												9. KUBIKEL	:	:	:							

NO	JURUSAN		OPSTYK KABEL		BEBAN DAN NH FUSE TERPASANG FUSE (A)										TEGANGAN UJUNG						BEBAN TRAF0		KETERANGAN
					R			S			T			N	RS	ST	RT	RN	SN	TN			
	KODE	JURUSAN PELAYANAN	TYPE	PENAMPANG KABEL	BEBAN	FUSE	COSØ	BEBAN	FUSE	COSØ	BEBAN	FUSE	COSØ	BEBAN	VOLT						KVA	%	
1	A		CU	4 X 95	230	BC		213	355		195	355		46				204	201	203	145,25	23,06	
2	B		CU	4 X 95	65	400		58	400		57	355		17							40,98	6,50	
3	C		CU	4 X 95	82	315		75	400		138	250		60							67,16	10,66	
4	D		CU	4 X 95	152	250		123	BC		141	BC		43							94,71	15,03	
5	E		CU	4 X 95	46	250		42	250		65	250		27							34,83	5,53	
6	F		CU	4 X 95	214	BC		131	300		164	BC		43							115,88	18,39	
7	G		CU	4 X 95	115	315		67	200		103	315		37							64,89	10,30	
8	H	KOSONG																					
9	I																						
10	J																						
JUMLAH					904			709			863			273							563,70	89,48	
JUMLAH TOTAL					2476									AMP							563,70	89,48	

CATATAN : _____

SPV. OPDIST. KBJ

PENGATUR

JAKARTA, 16 AGUSTUS 2018

PETUGAS

TITO SUJARWADI

NURYANTO

SUHARI / FERNANDO